

Abstract

- Kuli offers the possibility to simulate reversible systems for cooling and heating (simulation results verified by means of experiments)
- heat pump systems offer efficient and powerful possibility for supplementary heating
- thermal masses play an important role for transient behavior of entire cycle
- quasi steady state simulation does not deliver sufficient results for transient conditions
- principal transient behavior of entire cycle can be described with point masses
- for detailed investigations advanced external components can be used